

SEATTLE PUBLIC UTILITIES  
2007 WATER SYSTEM PLAN

II. WATER QUALITY AND TREATMENT

APPENDIX A  
**TREATMENT ASSETS INVENTORY**

*[This page left blank intentionally.]*

## Cedar Treatment Facility Design Criteria

### **Landsburg Diversion Dam**

#### **Chlorination**

System	Chlorine Gas
Target Dosage	0.65 to 1.7 mg/L

#### **Fluoridation**

System	Hydrofluosilicic Acid; Simple gravity feed
Target Dosage	1.15 mg/L

### **Lake Youngs**

#### **Plant**

Type:	Raw Water Ozonation and Ultra Violet Disinfection
Capacity:	180 mgd

#### **Intake and Raw Water Pump Station**

Pump type	Submersible
Number of units:	7
Size	2 @ 20 mgd, 5 @ 40 mgd

#### **Ozone Generation**

Type:	LOX Feed
Number of units:	2
Design concentration of ozone	6 - 12 %
Capacity:	825 lbs/day @ 12 % each (nominal) 1250 lbs/day @ 6 % each (peak)
Applied ozone dose	0.3 - 0.6 mg/L (typical) 0.8 mg/L (peak)

#### **Ozone Contacting**

Type:	Fine bubble diffusion
Flow direction	Counter-current
Contact type	Pipeline
Number of units:	Two parallel trains
Volume	0.61 MG
Contact time:	9.8 min @ peak capacity

#### **Ultra Violet Disinfection**

Design basis	3-log Cryptosporidium
Method	Medium pressure
Dosage	40 mJ/sq cm
Contact type	Closed vessel
Number	13 total, 12 @ 180 MGD
Capacity:	15 MGD each

#### **Clearwell**

Type:	Pre-stressed Concrete
Number of units:	2
Total volume:	20 MG

#### **Treatment Chemicals**

Gaseous chlorine:	Disinfectant residual
Lime:	pH and alkalinity adjustment
Sodium Bisulfite	Excess ozone quenching

*Source: Design Criteria (Updated July 12, 2004), CH2MHILL; Kirby, January 2006*

#### **Notes:**

lbs/day = pounds per day	mgd = million gallons per day
min = minutes	mg/L = milligrams per liter
LOX = Liquid Oxygen	MG = million gallons
mJ/sq cm = millijoules per square centimeter	

## Tolt Treatment Facility Design Parameters

<b>Plant</b>	
Type:	Direct Filtration with Raw Water Ozonation
Capacity:	120 mgd
<b>Ozone Generation</b>	
Type:	LOX Feed, High Concentration
Number of units:	Two duty, one standby
Capacity:	2,388 lbs/day each
Applied dose:	2.9 mg/l (average) 4.8 mg/l (maximum)
Production	1,651 lbs/day (average) 4,775 lbs/day (maximum)
<b>Ozone Contacting</b>	
Type:	Fine bubble diffusion w/baffled contactor
Number of units:	Two parallel trains
Capacity:	60 mgd each
Contact time:	31.6 minutes (theoretical), including dual-purpose flocculation/ozone contact basin
<b>Flocculation</b>	
Type:	Hydraulic flocculation w/baffled serpentine flow Pumped jet flash mix for chemical addition
Number of units:	Two parallel trains
Capacity:	60 mgd each
Detention time:	26.5 minutes (theoretical)
<b>Filtration</b>	
Type:	Anthracite mono-medium, with air/water backwash
Number of units:	Six (each with two bays)
Capacity:	24 mgd each
Rate:	12 gpm/sq ft
Bed depth:	72 inches
<b>Clearwell</b>	
Type:	Baffled concrete, cast-in-place
Number of units:	One (two equal halves)
Total volume:	7.4 MG
<b>Washwater Recovery</b>	
Type:	Settling/drying basins
Number of units:	Four
Capacity:	1.385 MG each
<b>FTW/Equalization Basin</b>	
Volume:	1.485 MG
<b>Treatment Chemicals</b>	
Ferric chloride:	Primary coagulant
Cationic polymer:	Coagulant aid
Anionic/nonionic polymer:	Filter aid and washwater solids settling aid
Gaseous chlorine:	Disinfectant residual
Carbon dioxide:	pH and alkalinity adjustment
Lime:	pH and alkalinity adjustment
Hydrofluosilicic acid:	Fluoride addition
Sodium bisulfite:	Excess ozone quenching

*Source: Process Design Criteria (February 2001), CDM PHILIP, SPU updated in April 2006*

### Notes:

FTW = Filter to Waste	mgd = million gallons per day
gpm/sq ft = gallons per minute per square foot	mg/L = milligrams per liter
lbs/day = pounds per day	MG = million gallons
LOX = Liquid Oxygen	

**Prepared April 2006**

---

**Seattle Well Fields Treatment Facilities**

---

Chlorination	System	Sodium Hypochlorite
	Target Dosage	1.0 to 1.4 mg/L
Fluoridation	System	Hydrofluosilicic Acid
	Target Dosage	1.0 mg/L
Corrosion Control	System	NaOH Addition
	Target pH	8.0

---

*Source: Updated by SPU in April 2006*

Reservoir and Well Chlorination Facilities					
Facilities	Year <sup>(1)</sup> Chlorination Facility Constructed	Type of Chlorination	Target Chlorine Residual (mg/l)	Redundancy	Condition
Outlet (Primary) Disinfection					
Beacon Hill Reservoir	1987	Sodium Hypochlorite	1.3	Two peristaltic pumps. Only one main storage tank	Upgraded in 2000
Maple Leaf Reservoir	1996	Sodium Hypochlorite	1.3	Excellent facility backup - two main storage tanks, peristaltic sodium hypochlorite injection equipment.	Facility is fairly new. Everything is in good shape.
Myrtle Reservoir	1957	Chlorine gas 150-lb cylinders	1.2	Only one chlorinator, to be removed in 2006 and replaced with on-site hypogeneration.	Treatment equipment is in good shape. Supplier supports equipment.
Roosevelt Reservoir	1996	Sodium Hypochlorite	1.35	Excellent facility backup - two main storage tanks, peristaltic sodium hypochlorite injection equipment.	Facility is fairly new. Everything is in good shape.
Volunteer Reservoir	1954	Chlorine gas 150-lb cylinders	1.3	Has one chlorinator and no sodium hypochlorite injection equipment or storage tanks.	Treatment equipment is in good shape. Supplier supports equipment.
West Seattle Gate House	1998	Sodium Hypochlorite	1.0	Excellent facility backup - two main storage tanks, peristaltic sodium hypochlorite injection equipment.	Facility is fairly new. Everything is in good shape.
West Seattle Reservoir	1998	Sodium Hypochlorite	1.3	Excellent facility backup - two main storage tanks, peristaltic sodium hypochlorite injection equipment.	Facility is fairly new. Everything is in good shape.
Residual Maintenance (Secondary) Disinfection					
Bitter Lake Reservoir	2001	On-site hypo generation	0.9	No redundancy/peristaltic with a spare on shelf. Can add calcium hypochlorite as a back up method.	Treatment equipment is in good shape.
Boulevard Park Well	1987	Sodium Hypochlorite	1.0	Well can be shut down if a disinfection equipment failure occurs.	Condition of the equipment is good. The sodium hypochlorite storage tanks were recently rebuilt.
Eastside Reservoir	1987	Sodium Hypochlorite	0.6	None. Can add calcium hypochlorite as a back up method of disinfection.	Treatment equipment is in good shape.
Lake Forest Park Reservoir	2002	On-site hypo generation	0.9	Two peristaltic pumps. Can add calcium hypochlorite as a back up method of disinfection.	Treatment equipment is in good shape.
Lincoln Reservoir	2004	On-site hypo generation	0.9	Two peristaltic pumps. Can add calcium hypochlorite as a back up method of disinfection.	Treatment equipment is in good shape.
Magnolia Reservoir	1994	Sodium Hypochlorite	0.9	Two storage tanks and two metering pumps.	Facility is fairly new. Good condition.
Riverton Well	1987	Sodium Hypochlorite	1.0	Peristaltic pumps. Well can be shut down if a disinfection equipment failure occurs.	Condition of the equipment is good. The sodium hypochlorite storage tanks were recently rebuilt.

Source: Reimer, 1999; Capron, 2006; Green, 2006

(1) In some cases, the year constructed is approximate.

SEATTLE PUBLIC UTILITIES  
2007 WATER SYSTEM PLAN

II. WATER QUALITY AND TREATMENT

APPENDIX B  
**ADMINISTRATIVE RULES FOR CROSS-CONNECTION  
CONTROL PROGRAM**

*[This page left blank intentionally.]*



# Seattle Public Utilities - Policy & Procedure

Subject: ADMINISTRATIVE RULES FOR THE CROSS-CONNECTION CONTROL PROGRAM	Number: SPU-CS-105
	Effective: 5-18-2006
	Supersedes: 400P-64-50, 4001-64-53, 4001-64-56, 4001-64-59
Approved: Chuck Clarke	Department: SPU
Page(s): 1 of 16	

## 1.0 PURPOSE

- 1.1 To establish administrative rules for the implementation of a program of cross-connection control in Seattle Public Utilities' direct service water supply area to protect the health of water consumers and the potability of the public water system. This rule supersedes three Department (SPU) Operating Instructions, 4001-64-53, Cross-Connection Inspection; 4001-64-56, Pier and Waterfront Inspection; and 4001-64-59, Backflow Prevention Device Installation and Testing, which are hereby rescinded.

## 2.0 ORGANIZATIONS AFFECTED

- 2.1 Seattle Public Utilities (SPU)
- 2.2 Public Health – Seattle King County (PHSKC), formerly Seattle-King County Department of Public Health
- 2.3 Seattle Department of Planning and Development (DPD)
- 2.4 City of Shoreline

## 3.0 REFERENCES

- 3.1 City of Seattle Cross-Connection Control Ordinance, Council File No. 115660, May 28, 1991. (See Appendix 1.)
- 3.2 2000 Uniform Plumbing Code (Chapter 6) and City of Seattle Amendments (Ordinance No. 14712, effective October 23, 1989).
- 3.3 Land Use Code, Zoning Code, SMC Titles 23 & 24.
- 3.4 WAC 246-290-490, Department of Health (DOH) Drinking Water Regulations, Cross-Connection Control.
- 3.5 WAC 296-24-12005, Department of Labor and Industries (DLI) Boilers and Unfired Pressure Vessels Law, Backflow Protection.
- 3.6 Cross-Connection Control Manual: Accepted Procedure and Practice, prepared by the Cross-connection Control Committee of the Pacific Northwest Section, American Water Works Association, Latest Edition.

- 3.7 Manual of Cross-Connection Control published by the Foundation for Cross-Connection Control and Hydraulic Research , University of Southern California (USC), Latest Edition.
- 3.8 Cross-Connection Joint Program Memorandum of Understanding with PHSKC and SPU, effective July 2001.
- 3.9 Backflow Prevention Assemblies Approved for Installation in Washington State, Washington State Department of Health, Latest Edition.
- 3.10 SPU Standard, Connection, and Administrative Charges Rule (Standard Charges), latest version.

#### 4.0 POLICY

- 4.1 It is the policy of Seattle Public Utilities to protect the public water supply and its water users as required and intended by state regulations by controlling each potential cross-connection as close to its source as practical.

#### 5.0 DEFINITIONS

- 5.1 Approved Backflow Prevention Assemblies: Assemblies that are approved by the State and appear on their published approval list and that are approved for use in the SPU direct service area; specifically, Reduced Pressure Backflow Assemblies (RPBA), Double Check Valve Assemblies (DCVA) and Pressure Vacuum Breaker Assemblies (PVBA). This applies to assemblies that, at time of original installation, were approved by the State, appeared on their published approval list current at that time, and were approved for use in the SPU direct service area. (See the definitions and descriptions provided in the Cross-Connection Control Manual: Accepted Procedure and Practice, Pacific Northwest Section, American Water Works Association, Latest Edition.)
- 5.2 Backflow: The flow of any foreign liquids, gases or other substances from any source, back into the potable water supply within a facility and/or public water supply. Backflow may occur due to either backsiphonage or backpressure.
- 5.3 Backflow Assembly Tester (BAT): A person holding a BAT certificate issued in accordance with WAC 246-290.
- 5.4 Backpressure: Backflow caused by positive pressure (above the supply pressure) in the piping system downstream of the supply piping.
- 5.5 Backsiphonage: Backflow caused by a negative pressure (vacuum) or reduced pressure in the supply piping.
- 5.6 Call-back Inspection: A follow-up inspection of a direct service customer's premises, performed by SPU to monitor the customer's activities toward achieving compliance subsequent to the cross connection inspection.
- 5.7 Contamination: Any impairment of the quality of the water from any substance

which may adversely affect the health of the consumer.

- 5.8 Controlled Cross-Connection: A connection between the SPU water system and any non-potable water system with an approved backflow prevention assembly properly installed and maintained so that it will continuously afford the protection commensurate with the degree of hazard.
- 5.9 Cross-Connection: Any physical arrangement whereby a public water supply is connected, or has the potential for being connected, directly or indirectly, with anything that does not exclusively contain or convey potable water from a Washington State Department of Health-approved source.
- 5.10 Cross-Connection Inspection: An inspection of a direct service customer's premises, performed by SPU, expressly for purposes of evaluating and locating cross-connection potential inherent in supplying that customer's water system.
- 5.11 Degree of Hazard: The degree of hazard is derived from an evaluation of the potential risk to public health and the adverse effect of the hazard upon the potable water system. Hazards may include:
  - 5.11.1 Health Hazard: Any condition, device or practice in the water supply system and its operation which, in the judgment of SPU, could create a danger to the health and well-being of the water customer.
  - 5.11.2 System Hazard: An actual or potential threat to the physical properties of, or to the potability of water in SPU's water system or the customer's potable water system, which would constitute a nuisance or be aesthetically objectionable or could cause damage to the system or its appurtenances, but would not be dangerous to health.
- 5.12 Seattle Public Utilities (SPU): SPU, the Director of SPU, his designee or his authorized agents. Authorized agents include the Customer Service Deputy Director, the Director of Utility Service Teams, the Supervisor of Utility Service Inspection, and Senior Utility Service Inspectors.
- 5.13 Direct Service Water Customer (or Water Customer): Those customers receiving water through a meter installed by SPU for end uses directly from the SPU distribution system and classed as direct service or retail for billing purposes.
- 5.14 Pollution: Any impairment of the quality of the water which may adversely affect the aesthetic characteristics of the water.
- 5.15 Potable Water Supply: Any water supply system intended or used for human consumption or other domestic uses and which must meet Washington State Department of Health Public Water System Rules and Regulations.
- 5.16 State: Washington State Department of Health, Office of Drinking Water.
- 5.17 Temporary Usage Connections: Any vehicle to which a tank or container is affixed for containing water and/or chemicals or materials, or any temporary use of water for construction, cooling, testing, or other non-domestic purposes which

are capable of imparting contamination or pollution to the public water supply through a cross-connection between such points of usage and the water supply via a fire hydrant or other temporary connection.

- 5.18 Water Service Connection: The terminal end of a service connection from the SPU water system; the city union, i.e., where SPU loses jurisdiction and sanitary control over the water at its point of delivery to the customer's water system. Service connection shall also include water service connections from a fire hydrant and all other temporary or emergency water service connections from the public potable water system.
- 5.19 Water System: For the purpose of this policy and procedure, the water system is considered to be made up of two parts: the SPU system and the customer's system. The SPU system shall consist of the source and transmission facilities and the distribution system, and shall include all those facilities of the water system under the complete control of SPU, up to the point where the customer's system begins. The customer's system shall include those parts of the facilities beyond the termination of SPU's distribution system which are utilized in conveying SPU-delivered water to points of use.

## 6.0 RESPONSIBILITIES

### 6.1 Seattle Public Utilities

- 6.1.1 SPU, through the Utility Service Inspection Unit of its Customer Service Branch, shall prevent contamination of the water distribution system and maximize protection of on-property water consumers by maintaining surveillance over new and existing plumbing within buildings to meet the requirements of the state regulations in cross-connection control. SPU has no responsibility or authority beyond the farthest downstream installed and operable backflow assemblies.

### 6.2 Water Customer

- 6.2.1 The water customer shall be responsible for eliminating cross-connections or controlling them through the installation, regular testing and maintenance of approved backflow prevention assemblies.
- 6.2.2 The water customer shall be responsible for providing the necessary information, obtaining required permits (including change of use permits) and providing entry and access for inspection, to allow a determination of the cross-connection, potential and the necessary control methods.
- 6.2.3 The water customer is responsible for notifying SPU of any assemblies which the customer believes are no longer required.

6.2.4 The water customer is responsible for all costs associated with the installation, testing, repair and replacement of backflow prevention assemblies.

6.2.5 The water customer is responsible for providing signs at all water takeoff points downstream of backflow prevention assemblies.

## 7.0 PROCEDURES

7.1 The following procedures represent minimum cross-connection control operating policies:

### 7.1.1 General

#### 7.1.1.1 Applicability of Regulations and References

7.1.1.1.1 The control or elimination of cross-connections shall be in accordance with the State of Washington Administrative Code on Cross-Connection Control (WAC 246-290-490) and the 2000 Edition of the Uniform Plumbing Code, Chapter 19.27 RCW, and subsequent additions.

7.1.1.1.2 The policies, procedures and criteria for determining appropriate levels of protection shall be in accordance with the Cross-Connection Control Manual: Accepted Procedure and Practice, Pacific Northwest Section, American Water Works Association, Latest Edition, and The Manual of Cross-Connection Control, Foundation for Cross-Connection Control and Hydraulic Research, University of Southern California (latest edition), with the following major exceptions:

7.1.1.1.2.1 Double Check Detector Assemblies and Reduced Pressure Detector Assemblies are approved for use in SPU's direct service area only as backflow assemblies and are not intended to take the place of any bypass meters retired on water services.

7.1.1.1.2.2 Services (fire/domestic) to buildings over three (3) stories or over 30 feet in height shall be protected with DCVAs. Backflow protection will not be required on service lines to existing systems exceeding three stories or 30 feet in height on a retrofit basis, unless, in the judgment of SPU, significant modifications to

the customer's water system, such as an increase of the service size, installation of booster pumps, or other changes that result in an increased ability to provide water flow, are being made during rehab construction.

7.1.1.1.2.3 Fire services constructed of materials which are not approved in the Uniform Plumbing Code or the City of Seattle Amendments for use in potable water piping systems shall be protected with DCVAs.

7.1.1.1.2.4 A Reduced Pressure Backflow Assembly or Air Gap is required for all Table #9 High hazard customers as referenced and required by WAC 246-290. In-premise protection is required by the City of Shoreline and PHSKC per the Cross-Connection Joint Program Memorandum of Understanding.

7.1.1.1.2.5 An Air Gap or Reduced Pressure Backflow Assembly is required on any aspirator-type equipment capable of introducing any substance into the water line downstream of such equipment.

#### 7.1.1.2 Guidelines for Type and Location of Protection

7.1.1.2.1 Type: The type of backflow protection required shall depend on the degree of hazard.

7.1.1.2.1.1 An air gap (AG) or Reduced Pressure Backflow Assembly (RPBA) shall be used if industrial waste or other similar toxic contamination is present that would cause a health or system hazard.

7.1.1.2.1.2 A double check valve assembly (DCVA) would be required if objectionable pollution (not hazardous to health) is present. Higher levels of protection, i.e., AG or RPBA, can be installed but would not be required.

7.1.1.2.1.3 A Pressure Vacuum Breaker Assembly (PVBA) and Spill-proof Vacuum Breaker Assembly (SVBA) would be required if objectionable pollution (not hazardous to health) is present, and there is no possibility of backpressure. Higher levels of protection, i.e., AG, RPBA or DCVA can be installed, but would not be required.

7.1.1.2.1.4 Any assembly required by these Administrative Rules shall be a model approved by the State of Washington Department of Health.

7.1.1.2.2 Location of Protection: The backflow protection shall be located as close to the hazard as practical and as required by WAC 246-290-490 and SPU. If access for inspection by SPU is denied by the water customer, in lieu of denying water service, and with the approval of PHSKC or the City of Shoreline, SPU may require that an AG or RPBA be installed at the property line or at agreed location with PHSKC or the City of Shoreline. An AG and RPBA would be required in those instances where SPU suspects sewage connected plumbing.

#### 7.1.1.3 Personnel Certification

7.1.1.3.1 At least one SPU staff member must be certified by the state as a Cross-connection Control Specialist (CCS). Normally, the Supervisor of the Utility Service Inspectors and two Senior Inspectors will have such certification.

#### 7.1.2 Plan Review of New and Rehab Construction

7.1.2.1 SPU's representative will review all new and rehab construction plans submitted to the Seattle Department of Planning and Development (DPD) that, by the description provided by the owner, may require cross-connection control. The cross-connection control requirements will be written on the Cross-Connection Plan Review form with attachments and returned to the architect or designer submitting the plans for review.

7.1.2.2 Water service will not be provided to new construction until the cross-connection control requirements are addressed.

7.1.2.3 NOTE: Owners are required by DPD to obtain Master Use Permits whenever the use of a building or lot changes in a way which would be regulated differently than the current use.

#### 7.1.3 Consultation

7.1.3.1 SPU representatives in the Utility Service Inspection Unit of the Customer Service Branch are available to review plans and interpret State Regulations and SPU Administrative Rules to assist water customers in meeting the cross-connection control ordinance and minimize retrofits and revisions.

#### 7.1.4 Inspection of Installations and Initial Assembly Testing

7.1.4.1 A SPU inspector shall jointly inspect all new installations of

backflow preventers on Table # 9 for high hazard water customers as referenced by WAC 246-290-490, and outlined in the Joint Program Memorandum of Understanding with PHSKC. All new backflow assemblies will be inspected after assemblies have been tested, and test report provided by a Washington State licensed Backflow Assembly Tester (BAT). (See Section 7.3.3 for annual testing requirements.) The owner and or installer is responsible for notifying SPU, City of Shoreline, or PHSKC of newly installed assemblies requiring inspection.

7.1.4.2 A SPU inspector shall inspect premises after the removal of any assembly which provides premise isolation. PHSKC will inspect in-premises assemblies no longer needed. An assembly no longer needed and for which the site was inspected, will be removed from SPU's records.

#### 7.1.5 Temporary Usage Inspections

7.1.5.1 A SPU inspector shall inspect equipment or processes for which a hydrant permit (see SPU's hydrant use policy and procedures) for temporary water service that has been requested and which poses a cross-connection potential, e.g., spray and tank trucks.

7.1.5.2 Corrections of deficiencies cited at the time of inspection must be completed before a hydrant permit will be issued.

7.1.5.3 Temporary users of water requesting a hydrant permit and whose use constitutes a cross-connection hazard, must produce an inspection certificate showing a current annual inspection, certified by SPU before a hydrant permit will be issued.

#### 7.1.6 Regular Inspections of High Hazard Sites

7.1.6.1 The Utility Service Inspection Unit shall assign priorities to and schedule high-hazard site inspections with special emphasis placed on the types of facilities listed in WAC 246-290-490. The Senior Utility Service Inspector shall notify the responsible party of the premises scheduled for inspection, and if possible, arrange a time that is convenient to the water customer.

7.1.6.1.1 NOTE: IF DURING THE INSPECTION, A CROSS-CONNECTION IS FOUND THAT PRESENTS, IN THE OPINION OF THE INSPECTOR, AN IMMINENT THREAT TO PUBLIC HEALTH, WATER SERVICE TO THE SITE SHALL BE IMMEDIATELY TERMINATED, AND SHALL REMAIN OFF UNTIL THE HAZARD IS CORRECTED.

7.1.6.2 After the inspection is complete, the Senior Utility Service Inspector shall notify the responsible party on the premises by a Site Survey letter listing the cross-connections found and



requesting their correction within a specified time. If an approved backflow prevention assembly is required on the customer's system, the type and location of the assembly shall be specified. A copy of the Site Survey shall be sent to PHSKC or the City of Shoreline, depending on the site location.

7.1.6.3 The water customer shall notify SPU at the completion of the work and a follow-up inspection will occur. If the work has been completed satisfactorily, then the Site Survey is abated and no further action will be needed.

7.1.6.4 If the water customer does not complete the work required in the letter of citation within the time specified, a second, certified letter will be sent requiring the water customer to complete the work within a shorter specified time (generally 10 days) and reminding the water customer that it is SPU's responsibility to deny water service to anyone who does not comply with backflow protection requirements.

7.1.6.5 If the water customer does not complete the work within the time specified in the second letter or does not make special arrangements with SPU for an alternate compliance date based on extenuating circumstances, SPU will give notice to the water customer of its intention to shut off water to the property on a specified date. On that date, the water service meter will be shut off and remain off until the backflow protection work has been completed.

7.2 The following represents required backflow prevention assembly installation practices.

#### 7.2.1 General

7.2.1.1 The criteria for assembly installation practices shall be in accordance with the Cross-Connection Control Manual: Accepted Procedure and Practice, Pacific Northwest Section, American Water Works Association, Latest Edition.

7.2.1.2 All new installations shall be inspected by SPU, the City of Shoreline, or PHSKC (per the Cross-Connection Joint Program Memorandum of Understanding).

7.2.1.3 Assemblies shall be accessible for testing and maintenance. They shall be installed no higher than five (5) feet above the floor or ground surface to the center line of the assembly, or be provided with an Occupational Safety and Health Administration (OSHA) approved work platform for assembly maintenance and testing.

7.2.1.4 Assemblies shall be protected against freezing, flooding and mechanical damage.

7.2.1.5 Assemblies shall not be installed in any enclosure or area containing fumes which are corrosive or toxic.

## 7.2.2 Air gap

7.2.2.1 An approved air gap shall mean a physical separation, unobstructed by guards, shields, or any other coverings, between the potable water supply system, measured vertically from the terminal point of the supply pipe to the overflow rim of the receiving vessel. This vertical, physical separation must be at least twice the diameter of the supply pipe but in no case shall this distance be less than one inch.

## 7.2.3 Reduced Pressure Backflow Assembly and Double Check Valve Assembly

7.2.3.1 RPBA's and DCVAs shall be installed per Washington State Department of Health List of Approved Backflow Assemblies.

7.2.3.2 RPBA's and DCVAs shall be installed with minimum clearances of 6 inches in front of test cocks, check valves, and relief valve covers to facilitate testing and maintenance. If an assembly is installed in an area with limited accessibility, such as a crawl space or pipe chase, a minimum of 24 inches clearance in front of test cocks shall be provided.

7.2.3.3 RPBA's and DCVAs shall be installed a minimum of 12 inches above ground or flood level, whichever is higher.

7.2.3.4 RPBA's shall not be installed in a below grade pit, vault, box, or chamber.

7.2.3.5 RPBA's shall be installed in a location where discharge from the relief port will not be objectionable, and shall be provided with an air-gapped drain which will reasonably handle the full discharge.

7.2.3.6 DCVAs shall be installed per WAC 246-290-490 Washington State Department of Health Approved Assemblies.

## 7.2.4 Pressure Vacuum Breaker Assembly (PVBA) and Spill-proof Vacuum Breaker (SVBA)

7.2.4.1 Shall be installed in accordance with the Cross-Connection Control Manual: Accepted Procedure and Practice, Pacific Northwest Section, American Water Works Association, Latest Edition, with the following major exception:

Vacuum breakers shall not be installed where there are any chemical addition capabilities, e.g., dishwasher supply lines with automatic detergent dispensing, chemical proportioners or

### 7.3.5 Quality Control Assurance Program

7.3.5.1 Testing reports require at a minimum: BAT certification number; test kit accuracy verification and/or calibration; test kit identification number; tested assembly make, model, serial number, and size; assembly location; and site hazard. SPU shall check BAT certification and proof of test kit accuracy.

7.3.5.2 SPU staff, certified as BAT, shall conduct periodic, random field verification of water customer's BAT assembly test results and reporting.

### 7.4 Incident Response

7.4.1 Water quality complaints concerning possible cross-connection incidents (e.g., gasoline, petroleum smell, blue water, etc.) will be responded to jointly by SPU, and either PHSKC or the City of Shoreline, depending on site location.

7.4.1.1 SPU will lead the off-premises investigation.

7.4.1.2 SPU will test the water at the meter.

7.4.1.3 PHSKC or the City of Shoreline, depending on the site location, will lead the investigation inside the facility to determine the problem.

7.4.2 SPU shall have a utility service inspector on-standby at all times to respond to potential incidents. SPU shall maintain 24-hour telephone call center with access to inspectors.

7.4.3 SPU shall maintain 24-hour contact information for PHSKC and the City of Shoreline.

### 7.5 Education

7.5.1 SPU shall educate consumers about cross-connection control through customer publications and community outreach.

### 7.6 Recordkeeping

7.6.1 SPU shall maintain a database for recordkeeping.

7.6.1.1 The database shall include at a minimum: listing of backflow prevention assemblies, assembly address and location, details of assemblies installed, site hazards, customer contact information, and inspection and testing information and results.

7.6.1.2 SPU and PHSKC shall be responsible for entering their own data into the SPU database.

7.6.2 SPU shall maintain on file backflow incident reports and program summary reports as required by WAC 246-290-490.

## 8.0 APPENDIX

- 1) City of Seattle Cross-Connection Control Ordinance, Council File No. 115660, May 28, 1991.

1           AUG    2  1991

APPENDIX 1

2                   ORDINANCE: 115660

3                   SEATTLE WATER DEPARTMENT

4   AN ORDINANCE relating to the Water Department, authorizing the  
5       Superintendent of Water to administer a cross-connection  
6       control program and to issue administrative rules therefor, and  
     amending SMC 21.04.070 to provide authority to administer such  
     program.

7   WHEREAS, a cross-connection is any physical arrangement whereby a  
8       public water supply is connected, directly or indirectly, with  
9       anything that does not exclusively contain or convey potable  
     water from a State-approved source; and

10   WHEREAS, Section 284-54 of the Washington Administrative Code Rules  
11       and Regulations governing Public Water Supplies requires that all  
     cross-connections are to be eliminated or controlled; and

12   WHEREAS, Section 248-54 of the Washington Administrative Code  
13       requires that in order to eliminate or control cross-  
     connections, every water purveyor is to establish a cross-  
     connection control program; and

14   WHEREAS, Seattle Water Department is the water purveyor (retail  
15       supplier) for the City of Seattle and for some adjacent  
     unincorporated areas of King County; and

16   WHEREAS, the Seattle Water Department must demonstrate  
17       administrative and enforcement authority for the purpose of  
     establishing a cross-connection control program acceptable to the  
IS       Department of Health; Now, Therefore,

19  
20   BE IT ORDAINED BY THE CITY OF SEATTLE AS FOLLOWS:

21       Section 1. The Superintendent of Water is authorized and  
22       directed to administer a cross-connection control program to protect  
23       the health of water customers and the potability of the public water  
24       system and to comply with the requirements of Washington law in  
25       connection therewith. The Superintendent of Water is authorized and  
26       directed to promulgate pursuant to SMC 3.02 rules and regulations  
27       to implement a cross-connection control program consistent with  
28       this authority. Said rules and regulations shall include but not be  
29       limited to:

30           1. Minimum cross-connection control operating policies;

31           2. Backflow prevention assembly installation practices;

32       and

          3. Backflow prevention assembly testing procedures.

1 Section 2. That SMC 21.04.070 (Ord. 65877 § 5 (part),  
2 1935) be amended as follows:

3 21.04.070 Cross Connections

4 A. ~~In no case shall any cross connection be allowed~~  
5 ~~between two or more City service connections, or between~~  
6 ~~any City service connection and pipe supplying water from~~  
7 ~~any other source.~~ Cross connections as defined in Section  
8 248-54 of the Washington Administrative Code (1991), or as  
9 may be amended, shall be eliminated or controlled in  
10 accordance with the administrative rules of the Water  
11 Department and any applicable rules of the State of  
12 Washington Department of Health or any other applicable  
13 City, State, or federal laws.

14 B. As a term and condition of all water service, the  
15 Superintendent of Water or his/her duly authorized  
16 representatives shall have a right to access at all  
17 reasonable times to all parts of the buildings or premises  
18 supplied by water from the City for the purpose of  
19 ascertaining the need to eliminate or control cross-  
20 connections.

21 C. The Seattle Water Department shall deny or  
22 discontinue water service to any customer failing to  
23 cooperate in the elimination of cross-connections or the  
24 control of cross-connections through the installation,  
25 maintenance, testing or inspection of backflow prevention  
26 assemblies required by the Seattle Water Department.

27 D. When in the discretion of the Superintendent of  
28 Water appropriate circumstances so warrant, the  
29 Superintendent may charge the account of any customer who  
30 violates any applicable rules and regulations concerning  
31 cross connections for all costs, including service calls,

aspirators, etc.

7.3 The following represents backflow prevention assembly testing requirements.

7.3.1 General

7.3.1.1 Annual testing of backflow assemblies shall be per WAC 246-290-490.

7.3.1.2 Backflow assembly testing procedures shall be in accordance with WAC 246-290-490 and the Cross-Connection Control Manual: Accepted Procedure and Practice, Pacific Northwest Section, American Water Works Association, Latest Edition.

7.3.2 Initial Inspection

7.3.2.1 As indicated in Section 7.1.4, initial inspection of new assemblies shall be conducted by SPU per Table # 9 WAC 246-290-490 and the Cross-Connection Joint Program Memorandum of Understanding with PHSKC and SPU.

7.3.3 Annual Testing

7.3.3.1 All mechanical assemblies (RPBA, DCVA, PVBA, SVBA) shall be tested annually by a certified Backflow Assembly Tester. Testers are to follow the acceptable testing procedures approved by Washington State Department of Health. Notification of the requirement for testing will be done annually by the department to all water customers responsible for annual testing of their assemblies. Results of the test must be forwarded to SPU within 30 days of the date of the notification.

7.3.3.2 If no test results have been received within 30 days of notification, a second letter will be sent, requesting testing reports be forwarded to the Department within 10 days.

7.3.3.3 If no test results have been received within 30 days of notification, a late fee will be charged to the water account, based on SPU Standard Charges.

7.3.3.4 Water service may be terminated unless action is satisfactorily taken to test the backflow assembly(ies) and service may be discontinued until testing is completed and test reports provided to SPU.

7.3.4 Testing After Repair or Replacement

7.3.4.1 Testing after repair or replacement is required by WAC 246-290-490 & the Uniform Plumbing Code, chapter 6.

and any damages incurred by the Water Department in  
relation to such violation.

Section 3. Any act taken pursuant to the authority and  
prior to the effective date of this ordinance is hereby  
ratified and confirmed.

Section . . . This ordinance shall take effect and be in force thirty days from and after its passage and  
approval, if approved by the Mayor; otherwise it shall take effect at the time it shall become a law under the  
provisions of the city charter.

Passed by the City Council the 28<sup>th</sup> day of May, 1971,  
and signed by me in open session in authentication of its passage this 28<sup>th</sup> day of  
May, 1971.  
President..... of the City Council.

Approved by me this 1<sup>st</sup> day of June, 1971.  
Norman B. Fie  
Mayor.

Filed by me this 4<sup>th</sup> day of June, 1971.

Norman J. Brooks  
Attest:.....  
City Comptroller and City Clerk.

(SEAL)

Published.....

By Margaret Carter  
Deputy Clerk.



SEATTLE PUBLIC UTILITIES  
2007 WATER SYSTEM PLAN

II. WATER QUALITY AND TREATMENT

APPENDIX C  
**COMPREHENSIVE DRINKING WATER QUALITY  
MONITORING PLAN**

*[This page left blank intentionally.]*

# Seattle Public Utilities

## Comprehensive Drinking Water Quality Monitoring Plan

January 20, 2006

---

### 1.0 Overview

Providing public health protection is a primary concern in the operation and maintenance of a public drinking water system. Determining the adequacy of this protection is accomplished with a comprehensive monitoring program that covers the source of supply, treatment systems, the distribution system, and customers' taps. Sampling requirements are established by federal regulations, such as the Safe Drinking Water Act (SDWA), which are in most cases adopted by the state. Seattle Public Utilities (SPU) conducts monitoring in accordance with the Safe Drinking Water Act and Washington State Department of Health requirements, Chapter 246-290 WAC.

This monitoring plan addresses the following:

- Monitoring requirements under state and federal drinking water regulations;
  - Future regulations, which are currently under development at the federal level;
  - Non-regulatory monitoring, which SPU conducts for informational purposes and to assist in operating the water system;
  - Sampling procedures;
  - Laboratory Information Management System (LIMS); and,
  - All parameters, locations, and frequency of monitoring conducted by SPU.
- Monitoring locations include source, treatment, transmission and distribution system, and customer taps.

A summary of SPU's monitoring requirements is shown in Table 1. This table includes source water and distribution system monitoring required by regulation. Monitoring of treatment operations required by the Surface Water Treatment Rule or Lead and Copper Rule is not included in Table 1, but is discussed below, and is reflected in Table 2.

Table 2 is a summary of the monitoring currently conducted by SPU and is organized by sampling locations, frequencies, and parameters. This table includes monitoring required by regulations, and monitoring conducted for operational or informational purposes (non-regulatory). All monitoring shown is directly related to the drinking water supply. Monitoring related to special studies, customer inquiries, disinfection of new mains, construction of facilities, environmental compliance when dewatering facilities, wellhead protection, aquifer recharge, source development, treatment chemicals, or other monitoring conducted for purposes other than drinking water quality compliance is not included in this document.

DOH has the authority to grant waivers for certain parameters, depending on vulnerability and previous sampling results. If a system is considered to have low vulnerability to contamination from a certain chemical or group of chemicals, the State may waive the requirements for

sampling, or reduce the amount of samples required. The State issued waivers for SPU for Volatile Organic Chemicals (VOCs) and Synthetic Organic Chemicals (SOCs) for the 2002 to 2004 monitoring period. SPU has applied for waivers for the 2005 to 2007 monitoring period. There are also several area-wide waivers in effect for several of the SOCs. These waivers apply to all systems within the designated area.

SPU operates its own State-certified laboratory for a majority of the parameters monitored. This includes total coliform, fecal coliform, HPC, most inorganic chemicals, trihalomethanes, haloacetic acids, lead, copper, and all SWTR parameters. Samples for VOCs, SOCs, asbestos, some inorganics, and *Cryptosporidium* and *Giardia* are sent to other laboratories certified by the state or EPA for the analysis.

Adjustments to monitoring are often required based on operational considerations, detection of organic chemicals, construction projects, or as required by the state based on a public health concern. SPU will work with the State to determine appropriate changes to the monitoring program to address any concerns that may arise.

## **2.0 Monitoring Requirements**

The following summarizes the monitoring requirements for existing and future regulations. Existing regulations include those finalized by EPA and published in the Federal Register under 40 CFR Part 141. Any regulation the state has adopted into Chapter 246-290 WAC with changes or additions are also discussed under existing regulations. Future regulations include those currently proposed by EPA.

### **2.1 Existing Regulations**

The existing regulations discussed below are organized by their common name with a reference to the appropriate federal and state section numbers.

#### ***Total Coliform Rule (40 CFR 141.21 and WAC 246-290-300 (3))***

SPU collects and analyzes coliform samples from representative points throughout the direct service area as outlined in SPU's Coliform Monitoring Plan. These samples are collected at designated sample stands according to established routes assigned by the Senior Water Quality Analyst or designee. Routes are designed to cover both the Cedar and Tolt service areas each day; with most sample stands being sampled weekly. For a system the size of SPU, at least 240 samples must be collected each month. The chlorine residual is also analyzed in the field at the time of coliform sample collection as required by state regulations. Temperature is also measured, although not required.

For any sample found to be positive for total coliform, or invalidated, follow-up action is taken according to state and federal regulations, as described in SPU's Coliform Monitoring Plan. This follow-up action may include additional sample collection, additional analyses such as fecal coliform, *E. Coli*, or HPC, and notification to the state. SPU's Coliform Monitoring Plan lists all

sample locations, schedules, test methods used, follow-up sampling requirements, and notification requirements.

### ***Surface Water Treatment Rule (40 CFR 141.70-75 and WAC 246-290 Part 6)***

The Surface Water Treatment Rule (SWTR) requires a significant amount of monitoring for SPU's filtered surface water supply, the South Fork Tolt River. This includes raw water, treated water, and distribution system water monitoring as follows.

*Raw Water Monitoring* – Continuous monitoring of turbidity at the inlet to the Tolt Treatment Facility occurs as required by the SWTR. Samples analyzed for fecal coliform density are collected at the inlet to the Tolt Treatment Facility daily, for at least 24 days a month.

*Treated Water Monitoring* – Treated water monitoring for the SWTR consists of monitoring required to determine the effectiveness of the disinfection process. This includes monitoring to determine log reduction of *Giardia* cysts and viruses. To determine the log reduction for virus, the pH, chlorine residual, temperature, clearwell volume, and peak hourly flow rate must be recorded. For the Tolt system, this monitoring is continuous, but is reported once a day at peak hourly flow. To determine the log reduction for *Giardia*, the pH, ozone residual at multiple locations along the contact chamber, temperature, and peak hourly flow are recorded. CT is calculated for each section of the ozone contact chamber. Ct is reported to the state for both the peak hourly flow and at minimum daily CT.

In addition, continuous chlorine residual monitoring for water entering the distribution system occurs at the outlet of the Tolt Treatment Facility. Turbidity is also monitored continuously at each individual filter unit and from the combined filter effluent.

Additional monitoring is conducted at the treatment plant to meet the requirements of the Service Agreement with the DBO contractor. This monitoring is summarized in Table 3.

*Distribution System Monitoring* – Residual disinfectant concentration is measured at the same time and location that a routine or repeat coliform sample is collected within the distribution system.

### ***Limited Alternative to Filtration (WAC 246-290-691)***

Beginning in November 2004, the Cedar water supply system was designated a Limited Alternative to Filtration status. As such, the source and treated water monitoring requirements are slightly different than an unfiltered surface water source subject to the SWTR. This includes raw water, treated water, and distribution system water monitoring as follows.

*Raw Water Monitoring* – Continuous turbidity monitoring occurs at the Cedar Water Treatment Facility for the raw water coming from Lake Youngs. Fecal coliform samples are also collected at this location once per day for a minimum of 24 days a month.

*Treated Water Monitoring* – Treated water monitoring consists of monitoring to determine inactivation of Giardia, Cryptosporidium, and viruses. This monitoring is conducted continuously for the ozonation system, UV treatment, and chlorination. For ozone inactivation of Giardia and viruses, monitoring includes temperature, pH, initial ozone concentration, ozone decay, and flow rate. For inactivation of Giardia and Cryptosporidium with UV, monitoring consists of flow rate through each reactor, UV transmission, UV dose, lamp power, and lamp hours. For inactivation of viruses with chlorine, monitoring includes flow rate, clearwell volume, pH, chlorine residual, and temperature.

Finished water entering the system is continuously monitored for chlorine residual, temperature and pH. Daily samples are also analyzed for coliform, although this is not required by regulation. Additional monitoring is required to meet the Service Agreement with the DBO contractor. Service Agreement monitoring is summarized in Table 3.

*Distribution System Monitoring* – Residual disinfectant concentration is measured at the same time and location that a routine or repeat coliform sample is collected within the distribution system.

***Disinfectants/Disinfection By-Products Rules (40 CFR 141.130-135, 141, 142) and WAC 246-290-300 (7)***

Current regulations (Stage 1) require trihalomethane (THMs) and haloacetic acids (HAAs) monitoring in the distribution system. SPU is required to collect two samples each quarter at existing sample stands within the direct service area under an approved reduced monitoring schedule. One of these stands is generally served by Cedar water and one is generally served by Tolt water. These two samples are collected at sample stands that are considered to represent the maximum residence time in the system for each source. Currently, sample stands G2 and B4 are considered to represent the maximum residence time for the Cedar and Tolt, respectively. SPU elects to collect two additional THM and HAA samples each quarter for informational purposes. The other two sites used are J-3 and A-3. These are considered average residence time and generally represent higher HAA levels.

Monitoring for chlorine residual currently conducted at total coliform sample sites in the direct service area are reported under the Stage 1 rule. Bromate and bromide monitoring are conducted for the Tolt and Cedar supplies now that ozonation facilities for each supply are in operation. The monitoring for bromate is conducted monthly at the entry to the distribution system. The bromide monitoring was conducted monthly for the source water prior to any treatment during the first year of operation of the Tolt and Cedar Treatment Facilities.

Stage 2 DBP Rule was finalized in January 2006. This new rule will require increased monitoring for DBPs, including a one year study of DBP levels at 24 distribution system locations in the direct service area. A monitoring plan must be submitted in October 2006, with monitoring beginning in 2007. Routine DBP monitoring under Stage 2 will likely require quarterly sampling at 12 locations

### ***Lead and Copper Rule (40 CFR 141.80-91)***

SPU has conducted monitoring for lead and copper at customers' taps according to the regulations and a Bilateral Compliance Agreement with DOH. Two rounds of samples were collected at 375 homes in 2003 and 2004 after completion of a corrosion control optimization study for the Tolt. Two more rounds of samples were collected at 400 homes in 2005. These homes were selected based on criteria in the Lead and Copper Rule. For the last two rounds, the homes were divided into sub regions. One hundred samples were collected from the Seattle direct service area, 100 were collected from Bellevue, 100 were collected from the participating wholesale providers receiving water from the Cedar supply, and 100 were collected from the participating wholesale providers receiving water from the Tolt supply. Compliance was based on the 90<sup>th</sup> percentile for each sub-region. The next round of monitoring will be conducted in 2006. Based on previous rounds, each sub-region qualifies for reduced monitoring, which requires 50 samples per sub-region. Eventually, each sub-region will likely be required to collect 50 samples once every three years. Monitoring requirements would change if the lead or copper action levels were exceeded.

Water quality parameter monitoring is also now required for the lead and copper rule. This monitoring currently includes collecting 25 distribution system samples each month and analyzing the samples for pH and alkalinity. Under reduced monitoring, 10 locations will likely be required.

### ***Inorganic Contaminants, VOCs, SOC's (40 CFR 141.23-23, 40 and WAC 246-290-300 (4) and (7))***

Primary and Secondary inorganic contaminants (IOCs) including arsenic, volatile organic chemicals (VOCs), and synthetic organic chemicals (SOCs) are monitored according to state and federal requirements. IOCs for the Cedar and Tolt supplies are monitored on an annual basis and VOCs are monitored once every three years, with the samples collected from the entry point to the distribution system, after treatment. This frequency assumes a state waiver has been granted for VOCs. The Riverton and Boulevard Park Wells are sampled once every three years (or when in operation) for IOCs and VOCs at the entry point to the distribution system prior to the first customer. SOC's are monitored as directed by the state, and the frequency is dependent on waiver status. SPU currently has a waiver for SOC monitoring through the year 2004.

### ***Radionuclides (40 CFR 141.26 and WAC 246-290-300 (9))***

The new radionuclides rule (effective December 2003) requires monitoring for gross alpha, radium 226, radium 228, and uranium. This monitoring is conducted for each source at the entry point to the distribution system. Frequency is dependent on results. After initial monitoring, samples will likely be required once every 9 years. Two consecutive quarterly samples will be required before December 2007 for initial monitoring.

### ***Fluoride (WAC 246-290-460)***

As required by state regulations, fluoride is monitored daily at each point of fluoride addition and a report is submitted to the state monthly. In addition to fluoride monitoring at the treatment plants, a grab sample is collected daily and analyzed at SPU's Water Quality Laboratory as a check.

### ***Unregulated Contaminants Rule (40 CFR 141.35, 40)***

The Unregulated Contaminants Rule, effective January 1, 2001, required additional monitoring for SPU's source waters. Four quarterly samples were collected at the entry point to the distribution system in 2002. If future UCMR regulations require monitoring sources in the future, SPU will be prepared.

## **2.2. Future Regulations**

The future regulations discussed below are organized by their currently accepted common name (may change in the future). *Federal Register* citations are provided for rules which have been published, either in draft or final form.

### ***Proposed Radon Rule (40 CFR 141.20)***

Monitoring for radon will be required in the future as a result of the new Radon Rule, proposed in October 1999. A final rule is expected in late 2007. This regulation may have the greatest impact on SPU's ground water supplies, as previous monitoring has not detected radon in the surface water supplies. SPU will be prepared to conduct any required monitoring for radon as a result of the new rule.

### ***Groundwater Rule***

This regulation is expected to be final in late 2006, with an effective date sometime in 2009. Additional monitoring of the disinfection treatment for the Riverton and Boulevard Park wells may be required due to this rule or a hydrogeological assessment and source water monitoring. It is not expected to have a significant impact on SPU's monitoring program.

### ***Cryptosporidium Monitoring for LT2SWTR (40 CFR Parts 9, 141, and 142)***

SPU currently conducts monthly source water monitoring for *Giardia* and *Cryptosporidium* for the Cedar and Tolt supplies. This monitoring is currently voluntary, but crypto monitoring will be required beginning in late 2006. The results of *Cryptosporidium* monitoring are reported in the annual Drinking Water Quality Report sent to customers each year. Currently, samples are collected from three locations: Landsburg forebay, Tolt Regulating Basin outlet, and Lake Youngs outlet prior to treatment.



## **2.3. Non-Regulatory Monitoring**

Non-regulatory monitoring discussed below includes monitoring performed for informational purposes or to assist in making operational decisions. This monitoring is not required by regulation at this time, but may be required at some time in the future.

### ***Limnology***

Monthly and quarterly monitoring of various limnological parameters is conducted at Lake Youngs, Chester Morse Lake, the Tolt Reservoir proper and reservoir tributary streams, and Cedar River tributary streams upstream of Landsburg. In addition, samples are collected occasionally from the Tolt Regulating Basin. This data is collected for informational purposes, and is not required by state or federal regulations. Sample collection occurs at multiple locations and depths in Lake Youngs, Chester Morse Lake, and the Tolt Reservoir. Some of the parameters included in sampling include temperature, dissolved oxygen, transparency, turbidity, conductivity, alkalinity, calcium, pH, phosphorous, iron, manganese, ultra-violet light absorption, total organic carbon, phytoplankton, zooplankton, taste and odor, geosmin, and MIB.

### ***Taste and Odor***

Taste and Odor are analyzed on a weekly or bi-weekly basis for each of SPU's large in-town reservoirs, the source waters, and other locations as needed. This monitoring is used to make operational decisions, but is not currently required by state or federal regulations.

### ***Reservoir Protection***

Each of SPU's in-town open reservoirs, and five closed reservoirs, currently have chlorination at the outlet, prior to entry to the distribution system. The chlorine residual is monitored continuously to ensure adequate treatment occurs at all times. In addition, weekly check samples are collected and analyzed by laboratory staff for chlorine, total coliform, fecal coliform, and HPC from the reservoir outlet and mid-reservoir. Treatment staff check each open reservoir treatment system daily. As required by WAC 246-290-470, SPU maintains and operates the open reservoirs according to a DOH approved Open Reservoir Protection Plan. In addition, DOH has approved SPU's Reservoir Covering Plan, which will replace, cover, or abandon all open reservoirs by 2018.

### ***Treatment Processes***

Existing source water treatment consists of ozonation, UV light, chlorination, fluoridation, and corrosion control on the Cedar supply. Treatment for the Tolt supply consists of ozonation, coagulation, flocculation, filtration, corrosion control, chlorination and fluoridation. Each of these processes is monitored continuously to ensure adequate treatment is maintained at all times. Portions of this monitoring are required by the regulations discussed above. Significantly more monitoring is required to meet the requirements of the Service Agreements for each DBO contractor operating the treatment plants. This monitoring is summarized in Table 3.

## **2.4 Sampling Procedures**

Proper sample collection is important for accurate results. All laboratory assistants and other staff collecting samples in the field are trained in appropriate sample collection techniques based on parameter. Written sample collection procedures for bacteriological analyses such as total coliform are included in SPU's Coliform Monitoring Plan. Sample collection methods for all regulatory compliance samples follow standard procedures or methods listed in *Standard Methods*. In addition, training for laboratory staff conducting the analyses occurs on a regular basis.

## **2.5 Laboratory Information Management System (LIMS)**

Beginning in 2006, SPU's Water Quality Laboratory implemented a new Laboratory Information Management System (LIMS). All water quality samples analyzed at the lab, or samples analyzed by outside laboratories for SPU's drinking water are entered into LIMS. This system provides the means to track sample status, record and validate results, and produce reports. Data from LIMS can then be extracted to other computer programs for long-term storage, analysis, or report formatting.

**Table 1**  
**Seattle Public Utilities**  
**Summary of Drinking Water Quality Monitoring Requirements (Regulatory)**  
Dated: January 20, 2006

Parameter	Locations	Frequency	Monitoring Year	Lab Used	Waivers	Comments
<b>Inorganic Chemicals</b>						
Antimony Arsenic Barium Beryllium Cadmium Chromium Copper Cyanide Fluoride Lead Mercury Nickel Selenium Sodium Thallium	SO1 at CLT-4, 5 SO2 at T-FINISH SO4 at BPW-T SO6 at RHW-T	Annually for Cedar and Tolt  Once every three years for wells	Every Year for SW  2007 for GW or when operating	SPU SPU SPU SPU SPU SPU Outside SPU SPU Outside SPU SPU SPU SPU		EPA and State allow waivers. State has not granted any to date.   No MCL, AL = 1.3 mg/L  No MCL, AI = 0.015 mg/L  Health Advisory Level = 20 mg/L
Nitrate Nitrite	CLT-4, 5, T-FINISH, RHW-T, BPW-T	Annually for SW and GW	Every Year, wells if operated	Outside		Sample during quarter with previous highest result (SW).
Asbestos	8426 36th Ave. SW (Cedar) 2033 NE 103rd St. (Tolt)	Once every nine years	Once in 2002-2011 period	Outside		Must be at a tap served by AC pipe. State waiver through 12/2001
Lead Copper	At 100 customer taps (almost 400 including purveyors)	After further optimization of Tolt corrosion control 2 rounds	2003 - 2004	SPU	BCA	We do roughly 100 for Tolt and 100 for Cedar
<b>Radionuclides</b>						
Gross Alpha Emitters Radium 226 Radium 228 Uranium	CLT-4, 5 T-FINISH, RHW-T, BPW-T	Initially 2 consecutive quarters, then frequency depends on results. Possibly once every 9 years.	By 2007 for SW  Next time Wells are used.	Outside		State Not Enforcing???
<b>Organic Chemicals</b>						
VOCs	CLT-4, 5, T-FINISH, RHW-T, BPW-T	Once every three years	2005-2007	Outside	Yes	State waivers for some
SOCs (Includes herbicides, general pesticides, & insecticides)	CLT-4, 5, T-FINISH, RHW-T, BPW-T	Depends on waiver	??	Outside	Yes	Waiting for waiver status from state
Dioxin, endoathall, Diquat, Glyphosate, EDB & other Soil Fumigants						State waivers
<b>Bacteriological</b>						
Total Coliform Rule	62 distribution system sample stands	240 samples per month	sampling conducted daily	SPU		Reduced monitoring for SPU may start soon
Chlorine Residual	Same locations as coliform	240 samples per month	sampling conducted daily	SPU		
<b>Disinfection By-Products</b>						
Trihalomethanes	G2, J3 for Cedar, A3, B4 for Tolt	Quarterly	Every Year	SPU		One sample is from extreme end of each source.
HAAs (future)	G2, J3 for Cedar, A3, B4 for Tolt	Quarterly	Every Year	SPU		Reduced monitoring for Stage 1 requires only one sample per quarter. Stage 2 IDSE in 2007/08.
<b>Secondary Contaminants</b>						
Chloride Color Fluoride Hardness Iron Manganese Silver Specific Conductivity Sulfate Total Dissolved Solids Zinc	CLT-4, 5, T-FINISH, RHW-T, BPW-T	Annually for Cedar and Tolt Once every three years for wells	Every Year for SW 2007 for GW	Outside SPU SPU SPU SPU SPU SPU SPU Outside SPU SPU		Only done if conductivity > 700 µmhos/cm
<b>Surface Water Treatment Rule (Tolt)</b>						
Turbidity	TPR-5S 5N, T-CFE, T-FINISH, each filter	Continuous				All Part of DBO Contract
Fecal coliform	TPR-5S 5N	Daily, at least 24 days per month		SPU		
Chlorine Residual	T-FINISH	Continuous				
CT Compliance	Ozone contactors and clearwell	Continuous				For Giardia and Virus inactivation
<b>Limited Alternative to Filtration (Cedar) - LAF</b>						
Turbidity	C1-RAW, C1-FIN, C2-FIN	Continuous				All Part of DBO Contract
Fecal coliform	C1-RAW	Daily, at least 24 days per month		SPU		
Chlorine Residual	C1-FIN, C2-FIN	Continuous				
CT Compliance	Ozone contactors, UV units, and clearwell	Continuous				For Crypto, Giardia, and Virus inactivation

**Table 2**  
**Seattle Public Utilities**  
**Drinking Water Quality Monitoring Conducted – by Parameter**  
**Required and Optional**

Parameter	Source	Monitoring Frequency and Location					
		Continuous	Daily or M-F	Weekly or Biweekly	Monthly	Quarterly	Annually
<b>Turbidity</b>	Cedar	CPR-1, C1-RAW, C1-FIN, C2-FIN	CPR-1, CT-2	Open reservoirs and checkpoints (6 sites)	10 sites on CMR, 11 sites on Lake Youngs	Part of QTR 8 sites	
	Tolt	TPR-5S 5N, T-FINISH, T-CFE, ea. Filter at plant, reclaimed water	TPR-4, TT-1, 2		10 sites Tolt Reservoir		
<b>pH</b>	Cedar	C1-RAW, C1-CWI, C1-FINISH	CPR-1, CLT-4, 5, CT-1, 2, 3,	Open reservoirs and checkpoints, Soos tanks, RVR-1, 41 TCR sites	CT-4, 10 sites on CMR, 11 sites on LYS, field pH at 25 TCR sites	4 DBP sites	
	Tolt	TPR-5S, T-FINISH, T-CWI	TT-1, 2, 11	TT-3, TT-22,	TPR-4, 10 sites Tolt Reservoir		
<b>Conductivity</b>	Cedar	WSP-1???	CPR-1, CLT-4, 5, CT-1, 2, 3,	Open reservoirs and checkpoints, Soos tanks, RVR-1, 41 TCR sites	CT-4, 10 sites on CMR, 11 sites on LYS, field pH at 25 TCR sites	4 DBP sites	
	Tolt		TT-1, 2, 11	TT-3, TT-22,	TPR-4, 10 sites Tolt Reservoir		
<b>Fluoride</b>	Cedar	CPT-00	CPT-00, CT-2	5 sample stands	Average of 11 seepage samples, 4 purveyors check samples	8 QTR sites	
	Tolt	T-FINISH	TT-1, 2	2 sample stands, TT-3, T-FINISH			
<b>Chlorine Residual</b>	Cedar	CPT-00, 4 location at CWTF, ESR, MGR, open reservoirs, Ballard firehouse	CLT-4, 5, CT-1, 2, 3, open reservoirs, CPT-00 2/shift	Closed tanks, standpipes, and reservoirs, open reservoirs and checkpoints, WSP-1, CPT-04, CT-4, almost 200 TCR sites DSA and WSA	25 PBCU sites	4 DBP sites, QTR sites	
	Tolt	T-FINISH, LFP, BLR	TT-1, 2, 11				
<b>Total Coliform - PA</b>	Cedar		CLT-4,5, CT-1, 2, 3, C1 and C2-FIN	Closed tanks, standpipes, and reservoirs, open reservoirs and checkpoints, CT-4, TT-3, WSP-1, almost 200 TCR sites (DSA and WSA)			
	Tolt		T-FINISH TT-1, 2, 11				

**Table 2**  
**Seattle Public Utilities**  
**Drinking Water Quality Monitoring Conducted – by Parameter**  
**Required and Optional**

Parameter	Source	Monitoring Frequency and Location					
		Continuous	Daily or M-F	Weekly or Biweekly	Monthly	Quarterly	Annually
<b>Total Coliform – Colisure QT</b>	both		CPR-1, C1-RAW, TPR-5S	Open Reservoirs	10 sites LYR, 6 sites CMR		
<b>Fecal Coliform</b>	Cedar		CPR-1, C1-RAW, C1-FIN, C2-FIN	Open Reservoirs			
	Tolt		TPR-5S				
<b>HPC</b>	Cedar		CPR-1, C1-RAW, CLT-4, 5	Closed tanks, standpipes, and reservoirs, open reservoirs and checkpoints, WSP-1	Average of 120 TCR sites (SPU and WSA)		
	Tolt		TPR-5S, TT-1, 2, 11, T-FINISH				
<b>Temperature</b>	Cedar	C1-RAW, C1-FIN, C2-FIN	CPR-1, CLT-4, 5, CT-1, 2, 3, C1-FIN, C2-FIN	Closed tanks, standpipes, and reservoirs, open reservoirs and checkpoints, CT-4, TT-3, T-CFE, almost 200 TRC sites (DSA and WSA)	Pb/Cu sites (25)	DBP sites	
	Tolt	TPR-5S, 5N	TT-1, 2, 11, TPR-5S 5N, T-FINISH				
<b>UVA</b>	Both	CPR-1	CPR-1	TPR-5S, T-CFE	CLR-2, C1-RAW, CPT-4, CMR sites, Tolt Res sites		
<b>TOC</b>	Both			CPR-1, TPR-5S, T-CFE	6 sites CMR, 10 sites Tolt Res, 10 sites LYR		
<b>Taste and Odor</b>	Both			CPR-1, CT-2, C1-RAW, C1-FIN, C2-FIN, T-FINISH, open reservoirs	CPT-04, 05		
<b>Giardia/Crypto</b>	Both				CPR-1, C1-RAW, TPR-4		
<b>Alkalinity</b>	Both			TT-3, TT-22, T-FINISH	25 Pb/Cu sites	8 QTR sites	
<b>Inorganics</b>	Both					2 sample stands, CPR-1, C1-RAW, CLT-4 - 5, TPR-4, T-FINISH CMR-1	CLT-4 -5, T-FINISH

Note: Sampling for Riverton and Boulevard Park Wells is not included in this table.

**Table 3**  
**Seattle Public Utilities**  
**Drinking Water Quality Monitoring Conducted by DBO Contractors**  
**Continuous Monitoring**

Parameter	Tolt Treatment Facility					
	Reclaimed Water	Raw Water	Ozone Contactors	Filter Effluents	Combined Filter Effluent	Clearwell Effluent
Turbidity	X	X		X	X	X
Temperature		X				
pH		X			X	X
Particle Count		X		X(1)	X	
Ozone Concentration			X			
Chlorine Residual					X	X
Fluoride					X	X
Parameter	Cedar Water Treatment Facility					
	Raw Water	Ozone Contactors	UV Reactors	Clearwell Influent	Clearwell Effluent	Finished Water
Turbidity	X					X
Temperature	X					X
pH	X			X	X	X
Ozone Concentration		X				
UV Transmission, UV Dose			X			
Chlorine Residual				X	X	X

Tolt grab sample parameters include coliform, alkalinity, bromate, iron, sodium, taste and odor, TTHMs and HAAs SDS, Color, TOC, and UVA.

Cedar grab sample parameters include coliform, bromate, iron, chlorophyll, sodium, and taste and odor.